

## National Competitive Bidding (NCB)

### **CORRIGENDUM NO. I - Date: 02/03/2019**

Tender No. : 125 /MYS/MMD/2018-19 dated: 02/02/2019

Tender Name : Supply, Installation and Commissioning of 2nos. Energy Efficient Centrifugal Chiller - 650TR (with Buy-Back) at BRBNMPL, Mysuru

With reference to the above, the following Corrigendum may kindly be noted against the points mentioned

#### **POINT OF CONCERN - 1**

##### **Page No. 33**

Section VII : Technical Specifications & Scope of work

Clause No. : D - 1 : SCOPE OF WORK

##### **As per Original Tender Enquiry:**

Point No. (m) : Integration of chiller unit with existing BAS system for operation & monitoring is under Supplier's scope.

##### **Amended and Should be read as**

Point No. (m) : **Our existing BMS/BAS is BAC net Master-Slave / Token-Passing Trunk (BAC net MS/TP protocol) with ADS-Lite A Project Software supplied by M/s. Johnson Controls (I) Pvt. Limited, Bengaluru. Intending bidder having different communication protocol for Building Automation System other than the above protocol should provide necessary hardware and software interface for integration into our existing BMS/BAS. Integration of supplied chiller units with existing BAS system for operation & monitoring is under Supplier's scope. Bidders are required to include the same in their quote. However, if required so, BRBNMPL will provide necessary access to our database during installation for integration with our existing BMS/BAS System**

#### **POINT OF CONCERN - 2**

##### **Page No. 39**

Section VII : Technical Specifications & Scope of work

Clause No. : D - 17 : BUY-BACK

##### **As per Original Tender Enquiry:**

Point No. (m) : The Buy-Back of the existing Chiller unit – 2 Nos. (Running Condition) will be in the condition "as it is" and having following specifications.

##### **Amended and Should be read as**

Point No. (m) : The Buy-Back of the existing Chiller unit – **Two Nos. (Running Condition - Chiller Unit # 3 & 4 with individual weight of approx. 10.74 Tons)** will be in the condition "as it is" and having following specifications

**CORRIGENDUM NO. I - Date: 02/03/2019**

**Tender No. : 125 /MYS/MMD/2018-19 dated: 02/02/2019**

**Tender Name : Supply, Installation and Commissioning of 2nos. Energy Efficient Centrifugal Chiller - 650TR (with Buy-Back) at BRBNMPL, Mysuru**

**POINT OF CONCERN - 3**

**Page No. 31**

**Section VII : Technical Specifications & Scope of work**

**Clause No. : C - BILL OF QUANTITY (BOQ)**

**As per Original Tender Enquiry:**

**Point No. (11) - Flow Meter : Size : Suitable for 350mm dia.MS pipe.**

**Amended and Should be read as**

**Point No. (11) - Flow Meter : Size : Suitable for 300mm dia.MS pipe**

**POINT OF CONCERN - 4**

**AMENDMENTS IN DATES**

	<b>As per Original Tender Enquiry</b>	<b>Amended and Should be read as</b>
Date of Sale of tender documents	From 02/02/2019 to 05/03/2019 during office hours	<b>From 02/02/2019 to 19/03/2019 during office hours</b>
Closing date and time for receipt of tenders	06.03.2019 at 14.30 hours	<b>20/03/2019 at 14.30 hours</b>
Time and date of opening of tenders	06.03.2019 at 15.00 hours	<b>20/03/2019 at 15.00 hours</b>

**All other terms and conditions remain unchanged.**

***This Corrigendum – I is part and parcel of Tender No. : 125 /MYS/MMD/2018-19, dtd. 02/02/2019. Both the pages of this corrigendum is to be submitted along with Techno-Commercial Bid (Part – I) duly signed and sealed by authorised signatory.***

***Bidders who have already submitted their sealed offer have to submit both the pages of this corrigendum duly signed and sealed by authorised signatory and may submit their revised sealed offer within the amended date of submission. If revised sealed offer is not received within amended Closing date and time for receipt of tender, then original offer will be considered as valid offer.***

For & on behalf of BRBNMPL,

Dy. General Manager (MMD)  
BRBNMPL, Note Mudran Nagar, Mysuru