

National Competitive Bidding (NCB)

CORRIGENDUM NO. I - Date: 05/05/2018

Tender No. : 141 /MYS/MMD/2017-18 dated: 24/03/2018

Tender Name : Supply, Installation and Commissioning of Two Stage Oil Free Screw Air Compressor – 1400 CFM with Air-Dryer at BRBNMPL, Mysuru

With reference to the above, the following Corrigendum may kindly be noted against the points mentioned

POINT OF CONCERN - 1

Page No. 29

Section VII : Technical Specifications & Scope of work

Clause No. : C : SCOPE OF WORK

As per Original Tender Enquiry:

Point No. (9) : Supplier has to ensure Delivery Air should be dry and also meet the **ISO Class – 0** requirements

Amended and Should be read as

Point No. (9) : Supplier has to ensure Delivery Air should be dry and also meet the **ISO Class between 1 - 3 requirements with Pressure Dew Point (PDP) \leq (-) 20° C**

POINT OF CONCERN - 2

Page No. 34

Section VII : Technical Specifications & Scope of work

Compliance Statement for Supply, Installation and Commissioning of Two Stage Oil Free Screw Air Compressor – 1400 CFM with Air-Dryer

Clause No. : A (Compliance Statement – Technical & Scope of Work) – GENERAL TERMS AND CONDITIONS

As per Original Tender Enquiry:

SI No	Description	Specifications	Offered	Remarks, if any
06	Delivery Air standard	Dry and meet the ISO Class – 0 requirements	Accepted	

Amended and Should be read as

SI No	Description	Specifications	Offered	Remarks, if any
06	Delivery Air standard	Dry and meet the ISO Class between 1 - 3 requirements with Pressure Dew Point (PDP) \leq (-) 20° C	Accepted	

CORRIGENDUM NO. I - Date: 05/05/2018

Tender No. : 141 /MYS/MMD/2017-18 dated: 24/03/2018

Tender Name : Supply, Installation and Commissioning of Two Stage Oil Free Screw Air Compressor – 1400 CFM with Air-Dryer at BRBNMPL, Mysuru

POINT OF CONCERN - 3

ADDITIONAL TERMS AND CONDITIONS :

Page No. 36

Section IX: Qualification/ Eligibility Criteria

Experience & Past Performance:

Performance of the bidder in executing the previous contracts/orders of BRBNMPL, if any, shall be taken into account during technical evaluation. The bids of the tenderers who were unsuccessful in completing the previous orders of BRBNMPL without any valid reason are liable to be ignored /rejected.

POINT OF CONCERN - 4

AMENDMENTS IN DATES

	As per Original Tender Enquiry	Amended and Should be read as
Date of Sale of tender documents	From 24/03/2018 to 24/04/2018 during office hours	From 24/03/2018 to 22/05/2018 during office hours
Closing date and time for receipt of tenders	25.04.2018 at 14.30 hours	23/05/2018 at 14.30 hours
Time and date of opening of tenders	25.04.2018 at 15.00 hours	23/05/2018 at 15.00 hours

All other terms and conditions remain unchanged.

This Corrigendum – I is part and parcel of Tender No. : 141 /MYS/MMD/2017-18, dtd. 24/03/2018. Both the pages of this corrigendum is to be submitted along with Techno-Commercial Bid (Part – I) duly signed and sealed by authorised signatory.

Bidders who have already submitted their sealed offer have to submit both the pages of this corrigendum duly signed and sealed by authorised signatory and may submit their revised sealed offer within the amended date of submission. If revised sealed offer is not received within amended Closing date and time for receipt of tender, then original offer will be considered as valid offer.

For & on behalf of BRBNMPL,

Dy. General Manager (MMD)
BRBNMPL, Note Mudran Nagar, Mysuru