

LIMITED TENDER

CORRIGENDUM/AMENDMENT NO. I - Date: 11/11/2020



Tender No.: 073/MYS/MMD/2020-21 dated: 22/10/2020




Tender Name: SUPPLY OF FIREFIGHTING AUXILIARY EQUIPMENT TO BRBNMPL, MYSURU

The following contents of the Tender No. given above are amended as per details given below.


S.No.	Description	Original details as Per Tender	Revised Details as per Corrigendum/ Amendment no. I dated 11.11.2020	Reference Page number of Tender
1.	Date of Sale of tender documents	From 22.10.2020 to 17.11.2020 during office hours.	NO CHANGE	3
2.	Closing date and time for receipt of tenders	18.11.2020 at 10.30 hours.	NO CHANGE	4
3.	Time and date of opening of tenders	18.11.2020 at 11.00 hours.	NO CHANGE	4,6
4.	Change in Technical specifications & compliance statement of Section VII	As given below	As given below	33,34 & 35





ORIGINAL DETAILS AS PER TENDER [Reference Page number of Tender: 33 & 34]

Sl. No.	Technical specifications	Indicative Image for understanding purpose only
4	Control type (Spray with jet) Multi-purpose branch Make: Any reputed make meeting with specifications	
5	Universal branch (Spray with jet) Make: Any reputed make meeting with specifications	

6	Revolving head Make: Any reputed make meeting with specifications	
7	Foam Making branch 5x with pickup tube Make: Any reputed make meeting with specifications	
8	Jumbo jet (Curtin branch) Make: Any reputed make meeting with specifications	

REVISED DETAILS AS PER AMENDMENT/CORRIGENDUM I DATED 11.11.2020

Sl. No.	Technical specifications	Indicative Image for understanding purpose only
4	<p>Control type (Spray with jet) Multi-purpose branch (as per IS:7673-2004 or latest version)</p> <p>Technical specification : Pattern Type : Spray - Jet Hand Control Select O Flow Nozzle Flow : 300 lpm, 400lpm, 450 lpm, 500 lpm, 600 lpm to 950 LPM (110 to 210 GPM) Inlet size :2 ½" (63 mm) Pressure : 7 kg/cm2 Material : Stainless Steel Spray Angle : 120 Degree & 130 Degree.. Weight : Light weight Mode : jet ,spray and shut off Throw : Above 35 Mtr.. Hand controlled multipurpose branch: A branch which can be adjusted to give a jet or a spray or both, each being independently controllable</p>	

	<p>by the branchman. It can be completely shut-off also. Make: Any reputed make meeting with specifications</p>	
5	<p>Universal (Spray with jet) branch (as per IS: 2871-2012 or latest version) Specification type : ISI / Commercial. Metal : Gun Metal. Size : 2½ inch(63 mm), Hydrostatic Pressure for Body : 21 Kgf / Cm². Outlet : Jet and Spray. Make: Any reputed make meeting with specifications</p>	
6	<p>Revolving head (as per IS 906-1988 or latest version) 63mm male inst. inlet. 360 Degree working Inlet Connection : 2 ½ " Male Instantaneous Operating Pressure : 150 PSI Max. Flow : 65 GPM @ 100 PSI Make: Any reputed make meeting with specifications</p>	
7	<p>Foam Making branch 5x with pickup tube (as per IS:2097-2012 or latest version) FB5X Foam Making Branch Pipe Specifications: Material: aluminium alloy Foam branch pipe and pick up tube lpm: 225 lpm - throw length =18 to 25 mtr. Make: Any reputed make meeting with specifications</p>	
8	<p>Jumbo jet (Curtain branch) as per latest standard available in market Jumbo Water Curtain Nozzle <ul style="list-style-type: none"> • Flang Size: 65 mm flanged end (2.5") • Male INT. : 63MM MALE COUPLING • Flow at 6.9 bar (100 psi), 320 gpm/750 lpm • Jumbo Water Curtain Nozzle Make: Any reputed make meeting with specifications</p>	

Note: Bidders are advised to submit the revised compliance statement as per format given below.

BHARATIYA RESERVE BANK NOTE MUDRAN (Pvt.) LIMITED*(Wholly own subsidiary of Reserve Bank of India)*

Note Mudran Nagar, Mysuru- 570003

Tender document for SUPPLY OF FIREFIGHTING AUXILIARY EQUIPMENT TO BRBNMPL, MYSURU

PART-A: COMPLIANCE STATEMENT – TECHNICAL (Revised)

Sl. No.	Technical specifications	Whether Offered by the bidder Yes/No	Offered Make & Model (if any)	Offered warranty in Years	Remarks/deviations if any
1	Breathing apparatus each 1800 Litre capacity Weight 8Kg. Cylinder Valve M18. MASK- Full Face Mask Vision. Cylinder -300 Bar. Material Carbon Fiber Cylinder. Working Duration- 50 Minutes.				
2	Oxygen filling Air compressor for breathing apparatus with 300 bar air fillable capacity Pressure- 330 Bar Auto Cut Off Systems C.F.M 3.5 R.P.M- 2800 K.W-2.2 Volts-440 V, 3 Phase				
3	Battery charger with 50 Metre cable for charging 2 Nos. of batteries of fire tender vehicle with 12V 25 Plates at a time Rating: 12 AH				
4	Control type (Spray with jet) Multi-purpose branch (as per IS:7673-2004 or latest version) Pattern Type : Spray - Jet Hand Control Select O Flow Nozzle Flow : 300 lpm, 400lpm, 450 lpm, 500 lpm, 600 lpm to 950 LPM (110 to 210 GPM) Inlet size :2 ½" (63 mm) Pressure : 7 kg/cm ² Material : Stainless Steel Spray Angle : 120 Degree & 130 Degree.. Weight : Light weight Mode : jet ,spray and shut off Throw : Above 35 Mtr.. Hand controlled multipurpose branch: A branch which can be adjusted to give a jet or a spray or both , each being independently controllable by the branchman. It can be completely shut-off also.				

BHARATIYA RESERVE BANK NOTE MUDRAN (Pvt.) LIMITED*(Wholly own subsidiary of Reserve Bank of India)*

Note Mudran Nagar, Mysuru- 570003

Tender document for SUPPLY OF FIREFIGHTING AUXILIARY EQUIPMENT TO BRBNMPL, MYSURU

5	Universal (Spray with jet) branch (as per IS: 2871-2012 or latest version) Specification type : ISI / Commercial. Metal : Gun Metal. Size : 2½ inch(63 mm), Hydrostatic Pressure for Body : 21 Kgf / Cm ² . Outlet : Jet and Spray.				
6	Revolving head (as per IS 906- 1988 or latest version) 63mm male inst. inlet. 360 Degree working Inlet Connection : 2 ½ " Male Instantaneous Operating Pressure : 150 PSI Max. Flow : 65 GPM @ 100 PSI				
7	Foam Making branch 5x with pickup tube (as per IS:2097-2012 or latest version) FB5X Foam Making Branch Pipe Specifications: Material: aluminium alloy Foam branch pipe and pick up tube lpm: 225 lpm - throw length =18 to 25 mtr.				
8	Jumbo jet (Curtain branch) as per latest standard available in market Jumbo Water Curtain Nozzle • Flang Size: 65 mm flanged end (2.5") • Male INT. : 63MM MALE COUPLING • Flow at 6.9 bar (100 psi), 320 gpm/750 lpm • Jumbo Water Curtain Nozzle				
9	Trolley type Foam / Water Monitor. Standard Mounted LTB2 Swivel Joints, Locking system for Change in Directions, Bearings with S.S Ball in Survival Joints Performance test: 23kgs f/cm ²				

(Authorised Signatory of the bidder firm with date)

(Seal)

Note: These changes are applicable to all other places of tender including Page No(s) given above.

All other terms and conditions remain unchanged.

This Corrigendum/Amendment forms part of the referred Tender. This page of Corrigendum/Amendment is to be submitted along with Techno-Commercial Bid (Part – I) duly signed and sealed by authorised signatory.

Bidders who have already submitted their sealed offer have to submit the page of this Corrigendum/Amendment duly signed and sealed by authorised signatory within the closing date of submission.

For & on behalf of BRBNMPL,

Dy. General Manager (MMD)
BRBNMPL, Note Mudran Nagar, Mysuru