

## LIMITED TENDER ENQUIRY

### CORRIGENDUM NO. I - Date: 04/07/2018

Tender No. : 034/MYS/MMD/2017-18 dated: 21/06/2018

Tender Name: SUPPLY, INSTALLATION AND COMMISSIONING OF ONLINE UPS

With reference to the above, the following Corrigendum may kindly be noted against the points mentioned.

#### **POINT OF CONCERN - 1**

##### **Page No. 29**

Section VII: Scope of work & Technical Specifications

Clause No. : C: Technical Specifications (Schedule I Online UPS 2\*20 KVA)

##### **As per Original Tender Enquiry:**

Point No. (3): AC Input supply: 415 V ( $\pm 10\%$ ), 450 Hz ( $\pm 5$ ), 3 Phase 4 wire.

Point No. (4): AC Output supply: Nominal voltage 220 V ( $\pm 1\%$ ), 47-53 Hz, Single Phase

##### **Amended and should be read as**

Point No. (3): AC Input supply: 415 V ( $\pm 10\%$ ), **50 Hz** ( $\pm 5$ ), 3 Phase 4 wire.

Point No. (4): AC Output supply: Nominal voltage 220 V ( $\pm 1\%$ ), **50 Hz ( $\pm 1$  Hz)**, Single Phase

**Note: These changes are applicable at all other places of tender including point no. (3) & point no. (4) of page no. 32 - PART-A Compliance Statement – Technical (for Schedule I)**

#### **POINT OF CONCERN – 2**

##### **Page No. 30**

Section VII: Scope of work & Technical Specifications

Clause No. : D: Technical Specifications of Schedule II (Online UPS 1\*30 KVA)

##### **As per Original Tender Enquiry:**

Point No. (4): AC Output supply: 415 V, 50 Hz ( $\pm 0.1\%$ ), 3 Phase 4 wire

##### **Amended and should be read as**

Point No. (4): AC Output supply: 415 V, 50 Hz ( **$\pm 1$  Hz**), 3 Phase 4 wire

**Note: These changes are applicable at all other places of tender including point no. (4) of page no. 34 - PART-A Compliance Statement – Technical (for Schedule II)**

#### **All other terms and conditions remain unchanged.**

***This Corrigendum – I is part and parcel of Tender No. : 034 /MYS/MMD/2017-18, dtd. 21/06/2018.***

***This page of corrigendum is to be submitted along with Techno-Commercial Bid (Part – I) duly signed and sealed by authorised signatory.***

***Bidders who have already submitted their sealed offer have to submit the page of this corrigendum duly signed and sealed by authorised signatory within the closing date of submission.***

For & on behalf of BRBNMPL,

Dy. General Manager (MMD)

BRBNMPL, Note Mudran Nagar, Mysuru