

BHARATIYA RESERVE BANK NOTE MUDRAN (P) LIMITED
(Wholly owned Subsidiary of Reserve Bank of India)
RBNML (PO), Salboni - 721 132
Phone: 03227-280212, 280213
Fax: 03227- 280222

CORRIGENDUM NO. 1 to OPEN TENDER NO. 053/SAL/PUR/2022-23 dated 06/01/2023 for
SUPPLY, INSTALLATION, COMMISSIONING & TESTING OF
TOWER AIR CONDITIONERS - 4TR

Date: 06th February, 2023

With reference to the above tender, the following Corrigendum No. 1 may kindly be noted at the respective places mentioned.

Sl. No.	Description	Details as per Original tender	Details as per Corrigendum No. 1 dated 06/02/2023	Reference Page number of Tender
1.	Date of Sale of tender documents	From 06/01/2023 to 06/02/2023 during office hours	From 06/01/2023 to 20/02/2023 during office hours	3
2.	Closing date and time for receipt of tenders	07/02/2023 at 11.30 hours	21/02/2023 at 11.30 hours	1, 3
3.	Time and date of opening of tenders	07/02/2023 at 11.45 hours	21/02/2023 at 11.45 hours	1, 3, 5, 74
4.	Section VII: Technical Specifications	--	II. General Specifications: Point No. 7,8 & 11	36
5.	Section VII: Declaration by Tenderer Compliance Statement	--	A. <u>TECHNICAL:</u> <u>Point No. 7, 8 & 11</u>	39

Note: These changes are applicable at all other places of tender including Page Nos. given above.

All other terms and conditions remain unchanged.

This Corrigendum/Amendment forms part of the referred Tender. This page of Corrigendum / Amendment is to be submitted along with Techno-Commercial Bid (Part – I) duly signed and sealed by authorized signatory.

Bidders are requested to submit revised bids incorporating the above changes in their offers, if already submitted.

Yours faithfully,
For & On behalf of BRBNMPL

(D. A. Patil)
Deputy General Manager-MMD

**CORRIGENDUM NO. 1 to OPEN TENDER NO. 053/SAL/PUR/2022-23 dated 06/01/2023 for
SUPPLY, INSTALLATION, COMMISSIONING & TESTING OF
TOWER AIR CONDITIONERS - 4TR**

Date: 06th February, 2023

As per the Original Tender Enquiry
(Page No. 36-39 of original tender document)

Section VII: Technical Specifications

II. GENERAL SPECIFICATIONS:

Sl. No.	Description	Requirements / Specifications
1	Item Requirement	Tower type Air Conditioner
2	Each Tower AC Capacity	4 TR
3	Minimum Cooling capacity (In Watt)	Not less than 12,000 Watt
4	Minimum Cooling capacity (In BTU/Hr)	Not less than 40,000 BTU/Hr
5	Refrigerant (Eco-friendly)	R32 / R410-A or better
6	Rated Power Supply-Volts/Hz/Phase	415VAC +/- 10%, 50Hz +/- 3%, 3 phase
7	Compressor Type	Rotary / Twin Rotary
8	Airflow Minimum in High mode (CFM)	Not less than 1100
9	Sound level-DB (Indoor Unit)	Not more than 55
10	Condenser coil material	Anti-Corrosive / Blue Fin Copper condenser
11	Outdoor Unit	Outdoor unit have Rotary / Twin Rotary compressors and air cooled condensers suitable to operate at 48 ^o C ambient condition
12	Remote	Wireless LCD/ LED remote should be supplied with all units
13	Accessories	Good quality Copper Tube Insulation, Hard Drawn PVC Drain Pipe with ISI.
14	Product Catalogue / Leaflet	Original Product Catalogue / Leaflet of the offered Air Conditioner to be submitted along with Technical Bid.
15	Make	Blue Star/Carrier/Hitachi / Voltas /LG/ Daikin or Equivalent

(Page No. 39 of original tender document)

Declaration by Tenderer

(To be filled, signed & stamped and submitted along with Technical Bid Part -I)

COMPLIANCE STATEMENT

A. TECHNICAL:

Sl. No.	Description	Requirements / Specifications	Offered by Bidder	Deviation, if any
1	Item Requirement	Tower type Air Conditioner	YES	

**CORRIGENDUM NO. 1 to OPEN TENDER NO. 053/SAL/PUR/2022-23 dated 06/01/2023 for
SUPPLY, INSTALLATION, COMMISSIONING & TESTING OF
TOWER AIR CONDITIONERS - 4TR**

Date: 06th February, 2023

2	Each Tower AC Capacity	4 TR	YES	
3	Rated Power Supply- Volts/Hz/Phase	415VAC +/- 10%, 50Hz +/- 3%, 3 phase	YES	
4	Cooling Capacity	Not less than 12,000 Watt		Please specify
5	Cooling Capacity	Not less than 40,000 BTU/Hr		Please specify
6	Refrigerant (Eco-friendly)	R32 / R410-A or better		Please specify
7	Compressor Type	Rotary / Twin Rotary		Please specify
8	Airflow in High Mode	Not less than 1100 CFM		Please specify
9	Sound (Indoor Unit)	Not more than 55 DB		Please specify
10	Condenser Coil Material	Anti-Corrosive / Blue Fin Copper condenser		Please specify
11	Outdoor Unit	Outdoor unit have Rotary / Twin Rotary compressors and air cooled condensers suitable to operate at 48 ^o C ambient condition	YES	
12	Remote	Wireless LCD/ LED remote to be supplied with all units	YES	
13	Accessories	Good quality Copper Tube Insulation, Hard Drawn PVC Drain Pipe with ISI.	YES	
14	Standard Accessories like Electrical Cable, Copper Tube, Insulation Tube and Drain pipe are to be supplied with each unit along with Mounting Bracket, & required Refrigerant Gas. Cost included in Quote of Each Unit.		YES	
15	Necessary Cutting, Mending, Bending, Installation, Commissioning, Performance Testing and Training at BRBNMPL, Salboni is under Supplier Scope.		YES	
16	Documents : Original Product Catalogue / Leaflet of the offered Air Conditioner and Declaration for spares and service support for 07 Years .		SUBMITTED	
17	Make & Model Offered : Preferably Blue Star/Carrier /Hitachi / Voltas /LG/ Daikin or Equivalent		Make: Model:	Please specify the make & model
18	Country of origin		Please specify

Signature of the Authorized Signatory & Stamp:

**CORRIGENDUM NO. 1 to OPEN TENDER NO. 053/SAL/PUR/2022-23 dated 06/01/2023 for
SUPPLY, INSTALLATION, COMMISSIONING & TESTING OF
TOWER AIR CONDITIONERS - 4TR**

Date: 06th February, 2023

Amended and should be read as

Section VII: Technical Specifications

II. GENERAL SPECIFICATIONS:

Sl. No.	Description	Requirements / Specifications
1	Item Requirement	Tower type Air Conditioner
2	Each Tower AC Capacity	4 TR
3	Minimum Cooling capacity (In Watt)	Not less than 12,000 Watt
4	Minimum Cooling capacity (In BTU/Hr)	Not less than 40,000 BTU/Hr
5	Refrigerant (Eco-friendly)	R32 / R410-A or better
6	Rated Power Supply-Volts/Hz/Phase	415VAC +/- 10%, 50Hz +/- 3%, 3 phase
7	Compressor Type	Rotary / Twin Rotary / hermetically sealed Scroll compressor / Scroll compressor
8	Airflow Minimum in High mode (CFM)	Not less than 800
9	Sound level-DB (Indoor Unit)	Not more than 55
10	Condenser coil material	Anti-Corrosive / Blue Fin Copper condenser
11	Outdoor Unit	Outdoor unit have Rotary / Twin Rotary / hermetically sealed Scroll compressor / Scroll compressors and air cooled condensers suitable to operate at 48 ^o C ambient condition
12	Remote	Wireless LCD/ LED remote should be supplied with all units
13	Accessories	Good quality Copper Tube Insulation, Hard Drawn PVC Drain Pipe with ISI.
14	Product Catalogue / Leaflet	Original Product Catalogue / Leaflet of the offered Air Conditioner to be submitted along with Technical Bid.
15	Make	Blue Star/Carrier/Hitachi / Voltas /LG/ Daikin or Equivalent

(Page No. 39 of original tender document)

Declaration by Tenderer

(To be filled, signed & stamped and submitted along with Technical Bid Part -I)

COMPLIANCE STATEMENT

A. TECHNICAL:

Sl. No.	Description	Requirements / Specifications	Offered by Bidder	Deviation, if any
1	Item Requirement	Tower type Air Conditioner	YES	

**CORRIGENDUM NO. 1 to OPEN TENDER NO. 053/SAL/PUR/2022-23 dated 06/01/2023 for
SUPPLY, INSTALLATION, COMMISSIONING & TESTING OF
TOWER AIR CONDITIONERS - 4TR**

Date: 06th February, 2023

2	Each Tower AC Capacity	4 TR	YES	
3	Rated Power Supply- Volts/Hz/Phase	415VAC +/- 10%, 50Hz +/- 3%, 3 phase	YES	
4	Cooling Capacity	Not less than 12,000 Watt		Please specify
5	Cooling Capacity	Not less than 40,000 BTU/Hr		Please specify
6	Refrigerant (Eco-friendly)	R32 / R410-A or better		Please specify
7	Compressor Type	Rotary / Twin Rotary / hermetically sealed Scroll compressor / Scroll compressor		Please specify
8	Airflow in High Mode	Not less than 800 CFM		Please specify
9	Sound (Indoor Unit)	Not more than 55 DB		Please specify
10	Condenser Coil Material	Anti-Corrosive / Blue Fin Copper condenser		Please specify
11	Outdoor Unit	Outdoor unit have Rotary / Twin Rotary / hermetically sealed Scroll compressor / Scroll compressors and air cooled condensers suitable to operate at 48°C ambient condition	YES	
12	Remote	Wireless LCD/ LED remote to be supplied with all units	YES	
13	Accessories	Good quality Copper Tube Insulation, Hard Drawn PVC Drain Pipe with ISI.	YES	
14	Standard Accessories like Electrical Cable, Copper Tube, Insulation Tube and Drain pipe are to be supplied with each unit along with Mounting Bracket, & required Refrigerant Gas. Cost included in Quote of Each Unit.		YES	
15	Necessary Cutting, Mending, Bending, Installation, Commissioning, Performance Testing and Training at BRBNMPL, Salboni is under Supplier Scope.		YES	
16	Documents: Original Product Catalogue / Leaflet of the offered Air Conditioner and Declaration for spares and service support for 07 Years .		SUBMITTED	
17	Make & Model Offered : Preferably Blue Star/Carrier /Hitachi / Voltas /LG/ Daikin or Equivalent		Make: Model:	Please specify the make & model
18	Country of origin		Please specify

Signature of the Authorized Signatory & Stamp: